REPORT

Issued by an Accredited Testing Laboratory

Contact person
Bertil Jonsson
Department Building and Real Estate
+46 10 516 51 60
bertil.jonsson@ri.se

Date	Reference	Page
2025-05-21	1318981-5	1 (2)

Allemann GmbH
DE-93479 GRAFENWIESEN
Tyskland

Determination of Thermal Transmittance According to EN 12428:2013

(3 appendices)

Work requested

The thermal transmittance (U_D) for a sliding door made of wood was to be calculated. Heat losses are calculated based on the drawings and material data supplied by the client (appendix3).

Test object

Client:	Allemann GMBH
Size:	Complete door 4500 x 4030 mm
Type of door:	Swing door wood (one sealing levels)
Type of panels:	2 leafs
Drawings:	250772 POS 5

Calculation and test methods

Calculations where performed according to EN 12428:2013. The THERM 7.4 software was applied when calculating linear heat losses.

Profiles and panels are calculated according to EN 10077-2:2012. Areas and definition of joints are made according to EN 12631:2012. Point bridges and hardware components with has neglectable influence are calculated according to EN 10211:2017.

Values of the thermal conductivity and applied boundary conditions are shown in appendix 1.

Calculation result

Type	Door daylight size (W x H)	U_D
Swing door wood	4500 x 4030 mm	1.2 W/(m^{2}K)

The calculations that are only valid for the calculated positions are shown in greater detail in appendix 2.

This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

Accred. No. 1002
Testing
ISO/IEC 17025

Transaktion 09222115557547791183 Signerat BJ, EK

RISE Research Institutes of Sweden AB
Building physics & sustainable buildings - Building physics testing

Performed by



Bertil Jonsson

Examined by

Eva-Lotta Kurkinen

Appendices
1 Material data and boundary conditions
2 Calculation of thermal transmittance
3 Drawings

Transaktion 09222115557547791183 Signerat BJ, EK